



Remarks:

1. Glands: 1 off M20 x 1.5 and 1 off M16 x 1.5, Blanking plug 1 off M20 x 1.5

DRAWN James Souter	24/01/2024	<b>AMTECS LTD</b>	
CHECKED Oliver Young	31/01/2024		
QA		TITLE	
MFG		AMA3-IE3 90S (B5)	
APPROVED		SIZE A3	DWG NO AMA3-IE3 90S (B5)
		SCALE 1 / 4	REV
		SHEET 1 OF 1	

Specification	<b>IEC 60034-1</b>
Manufacturer	<b>AmTecs</b>
Motor type	<b>AMA3-IE3 90S6</b>
Rated power	<b>0.75 kW S1 Duty</b>
Speed	<b>955 rpm</b>
Voltage	<b>220V / 400V</b>
Frequency	<b>50 Hz</b>
Connection	<b>Delta / Star</b>
Full load current	<b>3.36 A / 1.93 A</b>
No-load current	
Enclosure	<b>IP55</b>
Insulation class	<b>F (temp. rise B)</b>
Max. ambient temp	<b>40 °C</b>
Max. altitude	<b>1000 mtr above sea level</b>
Comment	
Cable entry	<b>M20 x 1.5</b>
Construction	<b>Aluminium</b>
Weight	<b>20 Kg</b>
Type number	
Warranty	

Efficiency class	<b>IE3</b>
Load data	<b>100%</b>
Efficiency	<b>78.9 %</b>
Power factor	<b>0.71</b>
Sound pressure level (1m)	<b>51 dB(A)</b>
Resistance R20 (open)	
Resistance R20 (Delta)	
Full load torque	<b>7.5 Nm</b>
Starting / Full load torque	<b>1.9</b>
Pull up / Full load torque	
Pull out / Full load torque	<b>2.3</b>

Starting / Full load current (DOL)	<b>6</b>
Starting / Full load current (Y/D)	
Rotor Inertia	
Bearing DE	<b>6205</b>
Bearing NDE	<b>6205</b>

<b>AmTecs Ltd</b>	
Charnham Park, Hungerford Berkshire, RG17 0YT	
Tel: +44 (0) 1488 686970	sales@amtecs.co.uk
Fax: +44 (0) 1488 686968	www.amtecs.co.uk